



Industrie Service

Certificate No. **AM VR2 – 1508 – 143 EU**

TÜV SÜD Industrie Service GmbH, Test Body for Vapour Recovery Systems,  
Westendstraße 199, D-80686 Munich



hereby certifies that it has tested the following automatic monitoring system for petrol vapour recovery systems according per EN 16321-1, Appendix D:

Type of system: **"Automatic monitoring system"**

Product name: **VapourGate**

Manufacturer: **Dover Fueling Solutions**

Brand name: **Wayne Fueling Systems**

System components: Gas flow sensor: **Wayne VR Meter**

Control board: **Wayne Fueling Systems iGEM or iGEM2**

Deactivation time: To be set by the manufacturer only: min. 72 h max. 168 h

Indication of preset deactivation time: Time will be display in the dispenser display when key "4" is pressed on the remote control.

Based on ID: "AM VR2 – 1508 – 143 EU"

The monitoring system for vapour recovery systems corresponds to the state of the art as defined in "Directive 2009/126/EC" last amended by Directive 2014/99/EU".

Germany, Munich, 19/10/2018

Valid to 18/10/2020



Test Body for Vapour Recovery Systems

*Peter Szalata*

Peter Szalata